



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5A0617

Lafayette Central School District

Project Name: Lead Testing

Ronald Cooper
5597 Route 20 West
lafayette, NY 13084

Project / PO Number: N/A
Received: 01/17/2025
Reported: 02/07/2025

Analytical Testing Parameters

Client Sample ID: LAF- Elementary - 001 - Faucet - Room 100
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-01

Collected By: Anthony Vadala
Collection Date: 01/17/2025 7:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		02/04/25 1253	02/04/25 1446	DLO

Client Sample ID: LAF- Elementary 002 - Drinking Fountain - Outside Room 102
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-02

Collected By: Anthony Vadala
Collection Date: 01/17/2025 7:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		02/04/25 1253	02/04/25 1450	DLO

Client Sample ID: LAF- Elementary 003 - Faucet - Room 102
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-03

Collected By: Anthony Vadala
Collection Date: 01/17/2025 7:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0040	0.005 AL	0.0010	mg/L		02/04/25 1253	02/04/25 1451	DLO

Client Sample ID: LAF- Elementary 004 - Faucet - Room 103
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-04

Collected By: Anthony Vadala
Collection Date: 01/17/2025 7:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		02/04/25 1253	02/04/25 1453	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5A0617

Client Sample ID: LAF- Elementary 005 - Faucet - Room 104

Sample Matrix: Drinking Water

Lab Sample ID: J5A0617-05

Collected By: Anthony Vadala

Collection Date: 01/17/2025 7:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		02/04/25 1253	02/04/25 1455	DLO

Client Sample ID: LAF- Elementary 006 - Faucet - Room 105

Sample Matrix: Drinking Water

Lab Sample ID: J5A0617-06

Collected By: Anthony Vadala

Collection Date: 01/17/2025 7:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0010	0.005 AL	0.0010	mg/L		02/04/25 1253	02/04/25 1456	DLO

Client Sample ID: LAF- Elementary 007 - Faucet - Room 106

Sample Matrix: Drinking Water

Lab Sample ID: J5A0617-07

Collected By: Anthony Vadala

Collection Date: 01/17/2025 7:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		02/04/25 1253	02/04/25 1500	DLO

Client Sample ID: LAF- Elementary 008 - Faucet - Room 108

Sample Matrix: Drinking Water

Lab Sample ID: J5A0617-08

Collected By: Anthony Vadala

Collection Date: 01/17/2025 7:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		02/04/25 1253	02/04/25 1502	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5A0617

Client Sample ID: LAF- Elementary 009 - Guidance Sink 1
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-09

Collected By: Anthony Vadala
Collection Date: 01/17/2025 7:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0489	0.005 AL	0.0010	mg/L		02/04/25 1253	02/04/25 1504	DLO

Client Sample ID: LAF- Elementary 010 - Water Fountain- Outside Room 112
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-10

Collected By: Anthony Vadala
Collection Date: 01/17/2025 7:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		02/04/25 1253	02/04/25 1505	DLO

Client Sample ID: LAF- Elementary 011 - Faucet - Room 112
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-11

Collected By: Anthony Vadala
Collection Date: 01/17/2025 7:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0037	0.005 AL	0.0010	mg/L		02/04/25 1253	02/04/25 1507	DLO

Client Sample ID: LAF- Elementary 012 - Faucet - Room 107
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-12

Collected By: Anthony Vadala
Collection Date: 01/17/2025 7:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		02/04/25 1253	02/04/25 1509	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5A0617

Client Sample ID: LAF- Elementary 013 - Faucet - Room 109
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-13

Collected By: Anthony Vadala
Collection Date: 01/17/2025 7:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0011	0.005 AL	0.0010	mg/L		02/04/25 1253	02/04/25 1511	DLO

Client Sample ID: LAF- Elementary 014 - Faucet - Room 114
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-14

Collected By: Anthony Vadala
Collection Date: 01/17/2025 7:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0054	0.005 AL	0.0010	mg/L		02/04/25 1253	02/04/25 1512	DLO

Client Sample ID: LAF- Elementary 015 - Faucet - Room 111
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-15

Collected By: Anthony Vadala
Collection Date: 01/17/2025 7:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0013	0.005 AL	0.0010	mg/L		02/04/25 1253	02/04/25 1514	DLO

Client Sample ID: LAF- Elementary 016 - Faucet - Room 115
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-16

Collected By: Anthony Vadala
Collection Date: 01/17/2025 7:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0010	0.005 AL	0.0010	mg/L		02/04/25 1253	02/04/25 1518	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5A0617

Client Sample ID: LAF- Elementary 017 - Faucet - Room 116
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-17

Collected By: Anthony Vadala
Collection Date: 01/17/2025 7:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0027	0.005 AL	0.0010	mg/L		02/04/25 1253	02/04/25 1520	DLO

Client Sample ID: LAF- Elementary 018 - Faucet - Room 117
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-18

Collected By: Anthony Vadala
Collection Date: 01/17/2025 7:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0014	0.005 AL	0.0010	mg/L		02/04/25 1253	02/04/25 1521	DLO

Client Sample ID: LAF- Elementary 019 - Faucet - Room 118
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-19

Collected By: Anthony Vadala
Collection Date: 01/17/2025 7:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0057	0.005 AL	0.0010	mg/L		02/04/25 1253	02/04/25 1523	DLO

Client Sample ID: LAF- Elementary 020 - Drinking Fountain - Outside Room 118
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-20

Collected By: Anthony Vadala
Collection Date: 01/17/2025 7:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		02/04/25 1253	02/04/25 1525	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5A0617

Client Sample ID: LAF- Elementary 021 - Water Cooler - Outside Room 118
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-21

Collected By: Anthony Vadala
Collection Date: 01/17/2025 7:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		02/04/25 1254	02/04/25 1532	DLO

Client Sample ID: LAF- Elementary 022 - Faucet - Room 120
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-22

Collected By: Anthony Vadala
Collection Date: 01/17/2025 7:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0016	0.005 AL	0.0010	mg/L		02/04/25 1254	02/04/25 1536	DLO

Client Sample ID: LAF- Elementary 023 - Faucet - Room 119
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-23

Collected By: Anthony Vadala
Collection Date: 01/17/2025 7:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0500	0.005 AL	0.0010	mg/L		02/04/25 1254	02/04/25 1538	DLO

Client Sample ID: LAF- Elementary 024 - Drinking Fountain - Gym
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-24

Collected By: Anthony Vadala
Collection Date: 01/17/2025 7:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0044	0.005 AL	0.0010	mg/L		02/04/25 1254	02/04/25 1539	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5A0617

Client Sample ID: LAF- Elementary 025 - Faucet - Room 128
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-25

Collected By: Anthony Vadala
Collection Date: 01/17/2025 7:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0014	0.005 AL	0.0010	mg/L		02/04/25 1254	02/04/25 1541	DLO

Client Sample ID: LAF- Elementary 026 - Drinking Fountain -Outside Room 130
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-26

Collected By: Anthony Vadala
Collection Date: 01/17/2025 7:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0015	0.005 AL	0.0010	mg/L		02/04/25 1254	02/04/25 1542	DLO

Client Sample ID: LAF- Elementary 027 - Water Cooler - Outside Room 130
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-27

Collected By: Anthony Vadala
Collection Date: 01/17/2025 7:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0019	0.005 AL	0.0010	mg/L		02/04/25 1254	02/04/25 1547	DLO

Client Sample ID: LAF- Elementary 028 - Faucet - Room 132
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-28

Collected By: Anthony Vadala
Collection Date: 01/17/2025 7:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0010	0.005 AL	0.0010	mg/L		02/04/25 1254	02/04/25 1548	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5A0617

Client Sample ID: LAF- Elementary 029 - Faucet - Room 123
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-29

Collected By: Anthony Vadala
Collection Date: 01/17/2025 7:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0037	0.005 AL	0.0010	mg/L		02/04/25 1254	02/04/25 1550	DLO

Client Sample ID: LAF- Elementary 030 - Faucet - Room 134
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-30

Collected By: Anthony Vadala
Collection Date: 01/17/2025 7:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		02/04/25 1254	02/04/25 1551	DLO

Client Sample ID: LAF- Elementary 031 - Faucet - Room 136
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-31

Collected By: Anthony Vadala
Collection Date: 01/17/2025 7:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0015	0.005 AL	0.0010	mg/L		02/04/25 1254	02/04/25 1553	DLO

Client Sample ID: LAF- Elementary 032 - Kitchen Sink
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-32

Collected By: Anthony Vadala
Collection Date: 01/17/2025 7:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		02/04/25 1254	02/04/25 1556	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5A0617

Client Sample ID: LAF- Elementary 033 - Kitchen Sink

Sample Matrix: Drinking Water

Lab Sample ID: J5A0617-33

Collected By: Anthony Vadala

Collection Date: 01/17/2025 7:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		02/04/25 1254	02/04/25 1557	DLO

Client Sample ID: LAF- Elementary 034 - Kitchen Sink

Sample Matrix: Drinking Water

Lab Sample ID: J5A0617-34

Collected By: Anthony Vadala

Collection Date: 01/17/2025 7:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0029	0.005 AL	0.0010	mg/L		02/04/25 1254	02/04/25 1559	DLO

Client Sample ID: LAF- Elementary 035 - Kitchen Sink

Sample Matrix: Drinking Water

Lab Sample ID: J5A0617-35

Collected By: Anthony Vadala

Collection Date: 01/17/2025 7:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0099	0.005 AL	0.0010	mg/L		02/04/25 1254	02/05/25 1420	DLO

Client Sample ID: LAF- Elementary 036 - Kitchen Sink

Sample Matrix: Drinking Water

Lab Sample ID: J5A0617-36

Collected By: Anthony Vadala

Collection Date: 01/17/2025 7:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		02/04/25 1254	02/04/25 1605	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5A0617

Client Sample ID: LAF- Elementary 037 - Kitchen Sink
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-37

Collected By: Anthony Vadala
Collection Date: 01/17/2025 7:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		02/04/25 1254	02/04/25 1606	DLO

Client Sample ID: LAF- Elementary 038 - Cafeteria
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-38

Collected By: Anthony Vadala
Collection Date: 01/17/2025 7:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		02/04/25 1254	02/04/25 1608	DLO

Client Sample ID: LAF- Elementary 039 - Cafeteria
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-39

Collected By: Anthony Vadala
Collection Date: 01/17/2025 7:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		02/04/25 1254	02/04/25 1609	DLO

Client Sample ID: LAF- Elementary 040 - Faucet - Room 217
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-40

Collected By: Anthony Vadala
Collection Date: 01/17/2025 7:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0470	0.005 AL	0.0010	mg/L		02/04/25 1254	02/04/25 1611	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5A0617

Client Sample ID: LAF- Elementary 041 - Drinking Fountain - Outside Room 222
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-41

Collected By: Anthony Vadala
Collection Date: 01/17/2025 7:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0011	0.005 AL	0.0010	mg/L		02/04/25 1255	02/04/25 1649	DLO

Client Sample ID: LAF- Elementary 042 - Faucet - Room 215
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-42

Collected By: Anthony Vadala
Collection Date: 01/17/2025 7:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0020	0.005 AL	0.0010	mg/L		02/04/25 1255	02/04/25 1653	DLO

Client Sample ID: LAF- Elementary 043 - Faucet - Room 220
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-43

Collected By: Anthony Vadala
Collection Date: 01/17/2025 7:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0040	0.005 AL	0.0010	mg/L		02/04/25 1255	02/04/25 1655	DLO

Client Sample ID: LAF- Elementary 044 - Faucet - Room 213
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-44

Collected By: Anthony Vadala
Collection Date: 01/17/2025 7:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0705	0.005 AL	0.0010	mg/L		02/04/25 1255	02/04/25 1656	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5A0617

Client Sample ID: LAF- Elementary 045 - Faucet - Room 218
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-45

Collected By: Anthony Vadala
Collection Date: 01/17/2025 7:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0023	0.005 AL	0.0010	mg/L		02/04/25 1255	02/04/25 1658	DLO

Client Sample ID: LAF- Elementary 046 - Faucet - Room 211
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-46

Collected By: Anthony Vadala
Collection Date: 01/17/2025 7:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.332	0.005 AL	0.0010	mg/L		02/04/25 1255	02/04/25 1659	DLO

Client Sample ID: LAF- Elementary 047 - Faucet - Room 216
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-47

Collected By: Anthony Vadala
Collection Date: 01/17/2025 7:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0477	0.005 AL	0.0010	mg/L		02/04/25 1255	02/04/25 1704	DLO

Client Sample ID: LAF- Elementary 048 - Faucet - Room 207
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-48

Collected By: Anthony Vadala
Collection Date: 01/17/2025 7:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0123	0.005 AL	0.0010	mg/L		02/04/25 1255	02/04/25 1705	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5A0617

Client Sample ID: LAF- Elementary 049 - Faucet - Room 214

Sample Matrix: Drinking Water

Lab Sample ID: J5A0617-49

Collected By: Anthony Vadala

Collection Date: 01/17/2025 7:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0265	0.005 AL	0.0010	mg/L		02/04/25 1255	02/04/25 1707	DLO

Client Sample ID: LAF- Elementary 050 - Drinking Fountain - Outside Room 214

Sample Matrix: Drinking Water

Lab Sample ID: J5A0617-50

Collected By: Anthony Vadala

Collection Date: 01/17/2025 7:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		02/04/25 1255	02/04/25 1708	DLO

Client Sample ID: LAF- Elementary 051 - Water Cooler - Outside Room 214

Sample Matrix: Drinking Water

Lab Sample ID: J5A0617-51

Collected By: Anthony Vadala

Collection Date: 01/17/2025 7:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0010	0.005 AL	0.0010	mg/L		02/04/25 1255	02/04/25 1710	DLO

Client Sample ID: LAF- Elementary 052 - Faucet - Room 208

Sample Matrix: Drinking Water

Lab Sample ID: J5A0617-52

Collected By: Anthony Vadala

Collection Date: 01/17/2025 7:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0049	0.005 AL	0.0010	mg/L		02/04/25 1255	02/04/25 1713	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5A0617

Client Sample ID: LAF- Elementary 053 - Faucet - Room 202 (Lib)
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-53

Collected By: Anthony Vadala
Collection Date: 01/17/2025 7:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		02/04/25 1255	02/04/25 1714	DLO

Client Sample ID: LAF- Elementary 054 - Drinking Founatin - Outside Library
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-54

Collected By: Anthony Vadala
Collection Date: 01/17/2025 7:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		02/04/25 1255	02/04/25 1716	DLO

Client Sample ID: LAF- Elementary 055 - Faucet - Room 200
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-55

Collected By: Anthony Vadala
Collection Date: 01/17/2025 7:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0016	0.005 AL	0.0010	mg/L		02/04/25 1255	02/04/25 1717	DLO

Client Sample ID: LAF- ONS 001 - Kitchen Sink 1
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-56

Collected By: Anthony Vadala
Collection Date: 01/17/2025 8:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0010	0.005 AL	0.0010	mg/L		02/04/25 1255	02/04/25 1722	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5A0617

Client Sample ID: LAF- ONS 002 - Kitchen Sink 2
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-57

Collected By: Anthony Vadala
Collection Date: 01/17/2025 8:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		02/04/25 1255	02/04/25 1723	DLO

Client Sample ID: LAF- ONS 003 - Kitchen Sink 3
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-58

Collected By: Anthony Vadala
Collection Date: 01/17/2025 8:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		02/04/25 1255	02/04/25 1725	DLO

Client Sample ID: LAF- ONS 004 - Kitchen Sink 4
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-59

Collected By: Anthony Vadala
Collection Date: 01/17/2025 8:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		02/04/25 1255	02/04/25 1726	DLO

Client Sample ID: LAF- ONS 005 - Kitchen Sink 5
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-60

Collected By: Anthony Vadala
Collection Date: 01/17/2025 8:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		02/04/25 1255	02/04/25 1728	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5A0617

Client Sample ID: LAF- ONS 006 - Drinking Fountain - Cafeteria
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-61

Collected By: Anthony Vadala
Collection Date: 01/17/2025 8:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		02/04/25 1256	02/04/25 1735	DLO

Client Sample ID: LAF- ONS 007 - Drinking Fountain - Outside Room 118
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-62

Collected By: Anthony Vadala
Collection Date: 01/17/2025 8:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		02/04/25 1256	02/04/25 1740	DLO

Client Sample ID: LAF- ONS 008 - Water Cooler - Outside Room 118
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-63

Collected By: Anthony Vadala
Collection Date: 01/17/2025 8:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		02/04/25 1256	02/04/25 1741	DLO

Client Sample ID: LAF- ONS 009 - Drinking Fountain - Outside MO
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-64

Collected By: Anthony Vadala
Collection Date: 01/17/2025 8:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		02/04/25 1256	02/04/25 1743	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5A0617

Client Sample ID: LAF- ONS 010 - Water Cooler - Outside MO
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-65

Collected By: Anthony Vadala
Collection Date: 01/17/2025 8:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		02/04/25 1256	02/04/25 1744	DLO

Client Sample ID: LAF- ONS 011 - MO Sink
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-66

Collected By: Anthony Vadala
Collection Date: 01/17/2025 8:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		02/04/25 1256	02/04/25 1746	DLO

Client Sample ID: LAF- ONS 012 - Nurse Sink 1
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-67

Collected By: Anthony Vadala
Collection Date: 01/17/2025 8:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		02/04/25 1256	02/04/25 1750	DLO

Client Sample ID: LAF- ONS 013 - Nurse Sink 2
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-68

Collected By: Anthony Vadala
Collection Date: 01/17/2025 8:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		02/04/25 1256	02/04/25 1752	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5A0617

Client Sample ID: LAF- ONS 014 - Nurse Sink 3

Sample Matrix: Drinking Water

Lab Sample ID: J5A0617-69

Collected By: Anthony Vadala

Collection Date: 01/17/2025 8:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		02/04/25 1256	02/04/25 1753	DLO

Client Sample ID: LAF- ONS 015 - Faucet - Room 202

Sample Matrix: Drinking Water

Lab Sample ID: J5A0617-70

Collected By: Anthony Vadala

Collection Date: 01/17/2025 8:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0030	0.005 AL	0.0010	mg/L		02/04/25 1256	02/04/25 1755	DLO

Client Sample ID: LAF- ONS 016 - Faucet - Room 203

Sample Matrix: Drinking Water

Lab Sample ID: J5A0617-71

Collected By: Anthony Vadala

Collection Date: 01/17/2025 8:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0012	0.005 AL	0.0010	mg/L		02/04/25 1256	02/04/25 1756	DLO

Client Sample ID: LAF- ONS 017 - Faucet - Room 204

Sample Matrix: Drinking Water

Lab Sample ID: J5A0617-72

Collected By: Anthony Vadala

Collection Date: 01/17/2025 8:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		02/04/25 1256	02/04/25 1759	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5A0617

Client Sample ID: LAF- ONS 018 - Faucet - Room 208
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-73

Collected By: Anthony Vadala
Collection Date: 01/17/2025 8:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		02/04/25 1256	02/04/25 1801	DLO

Client Sample ID: LAF- ONS 019 - Faucet - Room 209
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-74

Collected By: Anthony Vadala
Collection Date: 01/17/2025 8:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0023	0.005 AL	0.0010	mg/L		02/04/25 1256	02/04/25 1802	DLO

Client Sample ID: LAF- ONS 020 - Faucet - Room 210
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-75

Collected By: Anthony Vadala
Collection Date: 01/17/2025 8:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0014	0.005 AL	0.0010	mg/L		02/04/25 1256	02/04/25 1804	DLO

Client Sample ID: LAF- ONS 021 - Drinking Fountain - Outside Room 210
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-76

Collected By: Anthony Vadala
Collection Date: 01/17/2025 8:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		02/04/25 1256	02/04/25 1808	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5A0617

Client Sample ID: LAF- ONS 022 - Faucet - Room 217 Teacher Room
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-77

Collected By: Anthony Vadala
Collection Date: 01/17/2025 8:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		02/04/25 1256	02/04/25 1810	DLO

Client Sample ID: LAF- ONS 023 - Faucet - Room 243
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-78

Collected By: Anthony Vadala
Collection Date: 01/17/2025 8:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		02/04/25 1256	02/04/25 1812	DLO

Client Sample ID: LAF- ONS 024 - Faucet - Room 246
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-79

Collected By: Anthony Vadala
Collection Date: 01/17/2025 9:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0046	0.005 AL	0.0010	mg/L		02/04/25 1256	02/04/25 1813	DLO

Client Sample ID: LAF- HS 001 - Faucet - Loading Dock (Mop Sink)
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-80

Collected By: Anthony Vadala
Collection Date: 01/17/2025 9:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0034	0.005 AL	0.0010	mg/L		02/04/25 1256	02/04/25 1815	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5A0617

Client Sample ID: LAF- HS 002 - Spigot - Locker Hall
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-81

Collected By: Anthony Vadala
Collection Date: 01/17/2025 9:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0038	0.005 AL	0.0010	mg/L		02/04/25 1257	02/04/25 1822	DLO

Client Sample ID: LAF- HS 003 - Drinking Fountain - Girls Locker Room
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-82

Collected By: Anthony Vadala
Collection Date: 01/17/2025 9:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		02/04/25 1257	02/04/25 1826	DLO

Client Sample ID: LAF- HS 004 - Drinking Fountain - Boys Locker Room
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-83

Collected By: Anthony Vadala
Collection Date: 01/17/2025 9:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		02/04/25 1257	02/04/25 1828	DLO

Client Sample ID: LAF- HS 005 - Drinking Fountain - Gym Lobby
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-84

Collected By: Anthony Vadala
Collection Date: 01/17/2025 9:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		02/04/25 1257	02/04/25 1829	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5A0617

Client Sample ID: LAF- HS 006 - Water Cooler - Gym Lobby
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-85

Collected By: Anthony Vadala
Collection Date: 01/17/2025 9:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		02/04/25 1257	02/04/25 1831	DLO

Client Sample ID: LAF- HS 007 - Ice Machine
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-86

Collected By: Anthony Vadala
Collection Date: 01/17/2025 9:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0023	0.005 AL	0.0010	mg/L		02/03/25 1425	02/04/25 1333	DLO

Client Sample ID: LAF- HS 008 - Drinking Fountain - Main Hall (Girls RR)
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-87

Collected By: Anthony Vadala
Collection Date: 01/17/2025 9:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0016	0.005 AL	0.0010	mg/L		02/04/25 1257	02/04/25 1832	DLO

Client Sample ID: LAF- HS 009 - Water Cooler - Main Hall (Girls RR)
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-88

Collected By: Anthony Vadala
Collection Date: 01/17/2025 9:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0016	0.005 AL	0.0010	mg/L		02/04/25 1257	02/04/25 1837	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5A0617

Client Sample ID: LAF- HS 010 - Faucet - Main Office Sink
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-89

Collected By: Anthony Vadala
Collection Date: 01/17/2025 9:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		02/04/25 1257	02/04/25 1838	DLO

Client Sample ID: LAF- HS 011 - Drinking Fountain - Main Hall (Boys RR)
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-90

Collected By: Anthony Vadala
Collection Date: 01/17/2025 9:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		02/04/25 1257	02/04/25 1840	DLO

Client Sample ID: LAF- HS 012 - Water Cooler - Main Hall (Boys RR)
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-91

Collected By: Anthony Vadala
Collection Date: 01/17/2025 9:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		02/04/25 1257	02/04/25 1843	DLO

Client Sample ID: LAF- HS 013 - Drinking Fountain - Music Hall
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-92

Collected By: Anthony Vadala
Collection Date: 01/17/2025 9:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		02/04/25 1257	02/04/25 1846	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5A0617

Client Sample ID: LAF- HS 014 - Water Cooler - Music Hall
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-93

Collected By: Anthony Vadala
Collection Date: 01/17/2025 9:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		02/04/25 1257	02/04/25 1848	DLO

Client Sample ID: LAF- HS 015 - Drinking Fountain - Room 112 Choral Room
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-94

Collected By: Anthony Vadala
Collection Date: 01/17/2025 9:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		02/04/25 1257	02/04/25 1849	DLO

Client Sample ID: LAF- HS 016 - Drinking Fountain - Room 114 Band Room
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-95

Collected By: Anthony Vadala
Collection Date: 01/17/2025 9:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		02/04/25 1257	02/04/25 1851	DLO

Client Sample ID: LAF- HS 017 - Faucet - Room 117 Kitchen
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-96

Collected By: Anthony Vadala
Collection Date: 01/17/2025 9:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0011	0.005 AL	0.0010	mg/L		02/04/25 1257	02/04/25 1855	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5A0617

Client Sample ID: LAF- HS 018 - Drinking Fountain - BP Hall
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-97

Collected By: Anthony Vadala
Collection Date: 01/17/2025 9:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		02/04/25 1257	02/04/25 1857	DLO

Client Sample ID: LAF- HS 019 - Water Cooler - BP Hall
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-98

Collected By: Anthony Vadala
Collection Date: 01/17/2025 9:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		02/04/25 1257	02/04/25 1858	DLO

Client Sample ID: LAF- HS 020 - Faucet - 129 - Nurse
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-99

Collected By: Anthony Vadala
Collection Date: 01/17/2025 9:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		02/04/25 1257	02/04/25 1900	DLO

Client Sample ID: LAF- HS 021 - Faucet - Room 131 S1
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-AA

Collected By: Anthony Vadala
Collection Date: 01/17/2025 9:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		02/04/25 1257	02/04/25 1901	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5A0617

Client Sample ID: LAF- HS 022 - Faucet - Room 131 S2
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-AB

Collected By: Anthony Vadala
Collection Date: 01/17/2025 9:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		02/04/25 1259	02/04/25 1909	DLO

Client Sample ID: LAF- HS 023 - Faucet - Room 131 S3
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-AC

Collected By: Anthony Vadala
Collection Date: 01/17/2025 9:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		02/04/25 1259	02/04/25 1913	DLO

Client Sample ID: LAF- HS 024 - Faucet - Room 131 S4
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-AD

Collected By: Anthony Vadala
Collection Date: 01/17/2025 9:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		02/04/25 1259	02/04/25 1914	DLO

Client Sample ID: LAF- HS 025 - Drinking Fountain - D Wing Corridor
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-AE

Collected By: Anthony Vadala
Collection Date: 01/17/2025 9:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		02/04/25 1259	02/04/25 1916	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5A0617

Client Sample ID: LAF- HS 026 - Faucet - Room 144
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-AF

Collected By: Anthony Vadala
Collection Date: 01/17/2025 9:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		02/04/25 1259	02/04/25 1918	DLO

Client Sample ID: LAF- HS 027 - Drinking Fountain - 2nd Floor Corridor (Girls RR)
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-AG

Collected By: Anthony Vadala
Collection Date: 01/17/2025 9:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		02/04/25 1259	02/04/25 1919	DLO

Client Sample ID: LAF- HS 028 - Water Cooler - 2nd Floor Corridor (Girls RR)
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-AH

Collected By: Anthony Vadala
Collection Date: 01/17/2025 9:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		02/04/25 1259	02/04/25 1924	DLO

Client Sample ID: LAF- HS 029 - Faucet - Room 204 Teachers Room
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-AI

Collected By: Anthony Vadala
Collection Date: 01/17/2025 9:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0029	0.005 AL	0.0010	mg/L		02/04/25 1259	02/04/25 1925	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5A0617

Client Sample ID: LAF- HS 030 - Faucet - Room 211 Library
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-AJ

Collected By: Anthony Vadala
Collection Date: 01/17/2025 9:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0081	0.005 AL	0.0010	mg/L		02/04/25 1259	02/04/25 1927	DLO

Client Sample ID: LAF- HS 031 - Faucet - Room 212
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-AK

Collected By: Anthony Vadala
Collection Date: 01/17/2025 9:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0442	0.005 AL	0.0010	mg/L		02/04/25 1259	02/04/25 1928	DLO

Client Sample ID: LAF- HS 032 - Water Cooler - 2nd Floor Corridor (Boys RR)
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-AL

Collected By: Anthony Vadala
Collection Date: 01/17/2025 9:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		02/04/25 1259	02/04/25 1930	DLO

Client Sample ID: LAF- HS 032 - Drinking Fountain - Wellness
Sample Matrix: Drinking Water
Lab Sample ID: J5A0617-AM

Collected By: Anthony Vadala
Collection Date: 01/17/2025 9:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		02/04/25 1259	02/04/25 1932	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5A0617

Client Sample ID: LAF- HS 033 - Water Cooler - Wellness

Sample Matrix: Drinking Water

Lab Sample ID: J5A0617-AN

Collected By: Anthony Vadala

Collection Date: 01/17/2025 9:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		02/04/25 1259	02/04/25 1934	DLO

Client Sample ID: LAF- HS 034 - Concessions Sink

Sample Matrix: Drinking Water

Lab Sample ID: J5A0617-AO

Collected By: Anthony Vadala

Collection Date: 01/17/2025 9:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0010	0.005 AL	0.0010	mg/L		02/04/25 1259	02/04/25 1936	DLO

Client Sample ID: LAF- DO 001 - Sink

Sample Matrix: Drinking Water

Lab Sample ID: J5A0617-AP

Collected By: Anthony Vadala

Collection Date: 01/17/2025 9:30

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0010	0.005 AL	0.0010	mg/L		02/04/25 1259	02/04/25 1937	DLO

Results in **bold** have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

AL:	US EPA Action Level
mg/L:	Milligrams per Liter
RL:	Reporting Limit
RPD:	Relative Percent Difference

Project Requested Certification(s)

Microbac Laboratories, Inc. - Dayville
11549

Microbac Laboratories, Inc., New York Division
NY Lab ID No.: 10795

New York State Department of Health

New York State Department of Health



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5A0617

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

*The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. **The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <https://www.microbac.com/standard-terms-conditions>.***

Reviewed and Approved By:

A handwritten signature in dark ink that reads "Shannon Weeks". The signature is written in a cursive, flowing style.

Shannon Weeks

Customer Relationship Coordinator

Reported: 02/07/2025 09:24

Tony 315-420-7876

Customer: LaFayette CSD
 Contact: Ronald Cooper
 Project: Lead In Water



Sampled By: Ronald Cooper
 Sampler Phone #: 315-530-5680

School County: Onondaga
 School Type:
 School Name: LaFayette CSD
 School ID:

Sampling Event Name: Lead Testing in School Drinking Water
 Building address: 5955 US Route 20 LaFayette, NY 130
 Building ID:

Lab ID	Sample Code	Sample Type	Fixture Code	Fixture Type	Fixture Type Use	Fixture Area Type	Fixture Location Description	Fixture Description	Building Floor #	Water Last Used		Sample Collected	
										Date	Time	Date	Time
1	LAF-ELEM-001	FIRST DRAW		Faucet, Cold	Non-Consumption		Rm 100		1			1/17	7AM
2	LAF-ELEM-002	FIRST DRAW		Drinking Water Fountain	Consumption		outside Rm102		1			11	11
3	LAF-ELEM-003	FIRST DRAW		Faucet, Cold	Consumption		Rm 102	WF1	1			11	11
4	LAF-ELEM-004	FIRST DRAW		Faucet, Cold	Non-Consumption		Rm 103		1			11	
5	LAF-ELEM-005	FIRST DRAW		Faucet, Cold	Non-Consumption		Rm 104		1			11	
6	LAF-ELEM-006	FIRST DRAW		Faucet, Cold	Non-Consumption		Rm 105		1			11	
7	LAF-ELEM-007	FIRST DRAW		Faucet, Cold	Non-Consumption		Rm 106		1			11	
8	LAF-ELEM-008	FIRST DRAW		Faucet, Cold	Non-Consumption		Rm 108		1			11	
9	LAF-ELEM-009	FIRST DRAW		Faucet, Cold	Non-Consumption		Guidance Sink1		1			11	
10	LAF-ELEM-010	FIRST DRAW		Drinking Water Fountain	Consumption		outside Rm 112	WF2	1			11	
11	LAF-ELEM-011	FIRST DRAW		Faucet, Cold	Non-Consumption		Rm 112		1			11	
12	LAF-ELEM-012	FIRST DRAW		Faucet, Cold	Non-Consumption		Rm 107		1			11	11
13	LAF-ELEM-013	FIRST DRAW		Faucet, Cold	Non-Consumption		Rm 109		1			11	11

Lafayette Central School District
 PM: Shannon Weeks



* HNO3 added to containers. 1/22/25 mrc
 OT # - J432022 -

14	LAF-ELEM-014	FIRST DRAW		Faucet, Cold	Non-Consumption	Rm 114		1			4/17	7AM
15	LAF-ELEM-015	FIRST DRAW		Faucet, Cold	Non-Consumption	Rm 111		1			11	11
16	LAF-ELEM-016	FIRST DRAW		Faucet, Cold	Non-Consumption	Rm 115		1			11	11
17	LAF-ELEM-017	FIRST DRAW		Faucet, Cold	Non-Consumption	Rm 116		1			11	11
18	LAF-ELEM-018	FIRST DRAW		Faucet, Cold	Non-Consumption	Rm 117		1			11	11
19	LAF-ELEM-019	FIRST DRAW		Faucet, Cold	Non-Consumption	Rm 118		1				
20	LAF-ELEM-020	FIRST DRAW		Drinking Water Fountain	Consumption	Outside RM 118	WF3	1				
21	LAF-ELEM-021	FIRST DRAW	Bottle Filler	Water Cooler	Consumption	Outside RM 118	BF3	1				
22	LAF-ELEM-022	FIRST DRAW		Faucet, Cold	Non-Consumption	Rm 120		1				
23	LAF-ELEM-023	FIRST DRAW		Faucet, Cold	Non-Consumption	Rm 119		1				
24	LAF-ELEM-024	FIRST DRAW		Drinking Water Fountain	Consumption	Gym		1				
25	LAF-ELEM-025	FIRST DRAW		Faucet, Cold	Non-Consumption	Rm128		1				
26	LAF-ELEM-026	FIRST DRAW		Drinking Water Fountain	Consumption	outside Rm130	WF5	1				
27	LAF-ELEM-027	FIRST DRAW	Bottle filler	Water Cooler	Consumption	outside Rm130	BF5	1				
28	LAF-ELEM-028	FIRST DRAW		Faucet, Cold	Non-Consumption	Rm 132		1				
29	LAF-ELEM-029	FIRST DRAW		Faucet, Cold	Non-Consumption	Rm123		1				
30	LAF-ELEM-030	FIRST DRAW		Faucet, Cold	Non-Consumption	Rm 134		1				
31	LAF-ELEM-031	FIRST DRAW		Faucet, Cold	Non-Consumption	Rm136		1				

HN03 added to each Containers.
 Lot Number - J432022 - 1/22/25 mrc

Lafayette Central School District
 PM: Shannon Weeks



32	LAF-ELEM-032	FIRST DRAW	Faucet, Cold	Non-Consumption	Kitchen Sink	1	1/17 7AM
33	LAF-ELEM-033	FIRST DRAW	Faucet, Cold	Consumption	Kitchen Sink	1	
34	LAF-ELEM-034	FIRST DRAW	Faucet, Cold	Consumption	Kitchen Sink	1	
35	LAF-ELEM-035	FIRST DRAW	Faucet, Cold	Consumption	Kitchen Sink	1	
36	LAF-ELEM-036	FIRST DRAW	Faucet, Cold	Consumption	Kitchen Sink	1	
37	LAF-ELEM-037	FIRST DRAW	Faucet, Cold	Consumption	Kitchen Sink	2	
38	LAF-ELEM-038	FIRST DRAW	Faucet, Cold	Non-Consumption	Cafeteria	2	
39	LAF-ELEM-039	FIRST DRAW	Faucet, Cold	Consumption	Cafeteria	WF 2	
40	LAF-ELEM-040	FIRST DRAW	Faucet, Cold	Non-Consumption	Rm 217	2	
41	LAF-ELEM-041	FIRST DRAW	Drinking Water Fountain	Non-Consumption	Outside Rm 222	WF 7 2	
42	LAF-ELEM-042	FIRST DRAW	Faucet, Cold	Non-Consumption	Rm 215	2	
43	LAF-ELEM-043	FIRST DRAW	Faucet, Cold	Non-Consumption	Rm 220	2	
44	LAF-ELEM-044	FIRST DRAW	Faucet, Cold	Non-Consumption	Rm 213	2	
45	LAF-ELEM-045	FIRST DRAW	Faucet, Cold	Non-Consumption	Rm 218	2	
46	LAF-ELEM-046	FIRST DRAW	Faucet, Cold	Non-Consumption	Rm 211	2	
47	LAF-ELEM-047	FIRST DRAW	Faucet, Cold	Non-Consumption	Rm 216	2	
48	LAF-ELEM-048	FIRST DRAW	Faucet, Cold	Non-Consumption	Rm 207	2	
49	LAF-ELEM-049	FIRST DRAW	Faucet, Cold	Non-Consumption	Rm 214	2	

HW03 added to each container
 Lot number - J482022-1/22/25 mrc

J 5 A 0 6 1 7
 Lafayette Central School District
 PM: Shannon Weeks



50	LAF-ELEM-050	FIRST DRAW		Drinking Water Fountain	Consumption		outside Rm 214	WF8 BF8	2			4/17	7Am
51	LAF-ELEM-051	FIRST DRAW	Bottle Filler	Water Cooler	Consumption		outside Rm 214		2				
52	LAF-ELEM-052	FIRST DRAW		Faucet, Cold	Non-Consumption		Rm 208		2				
53	LAF-ELEM-053	FIRST DRAW		Faucet, Cold	Non-Consumption		Rm 202 (lib)		2				
54	LAF-ELEM-054	FIRST DRAW		Drinking Water Fountain	Consumption		Outside lib	WF 9	2				
55	LAF-ELEM-055	FIRST DRAW		Faucet, Cold	Non-Consumption		Rm 200		2				
56	LAF-ONS-001	FIRST DRAW		Faucet, Cold	Consumption		Kitchen Sink 1		1				8Am
57	LAF-ONS-002	FIRST DRAW		Faucet, Cold	Consumption		Kitchen Sink 2		1				
58	LAF-ONS-003	FIRST DRAW			Consumption		Kitchen Sink 3		1				
59	LAF-ONS-004	FIRST DRAW			Consumption		Kitchen Sink 4		1				
60	LAF-ONS-005	FIRST DRAW			Consumption		Kitchen Sink 5		1				
61	LAF-ONS-006	FIRST DRAW		Drinking Water Fountain	Consumption		Cafeteria	WF 2	1				
62	LAF-ONS-007	FIRST DRAW		Drinking Water Fountain	Consumption		outside Rm 118	WF 1 BF 1	1				
63	LAF-ONS-008	FIRST DRAW	Bottle Filler	Water Cooler	Consumption		outside Rm 118		1				
64	LAF-ONS-009	FIRST DRAW		Drinking Water Fountain	Consumption		Outside MO	WF 3 BF 3	2				
65	LAF-ONS-010	FIRST DRAW	Bottle filler	Water Cooler	Consumption		Outside MO		2				
66	LAF-ONS-011	FIRST DRAW		Faucet, Cold	Consumption		MO Sink		2				
67	LAF-ONS-012	FIRST DRAW		Faucet, Cold	Consumption		Nurse sink 1		2				

J 5 A 0 6 1 7
Lafayette Central School District
PM: Shannon Weeks



HN03 added to each container
lot number - J432022-1/22/25 mrc

04 of 07

68	LAF-ONS-013	FIRST DRAW		Faucet, Cold	Consumption	Nurse sink 2		2			1/17 8AM
69	LAF-ONS-014	FIRST DRAW		Drinking Water Fountain	Consumption	Nurse sink 3		2			"
70	LAF-ONS-015	FIRST DRAW		Faucet, Cold	Non-Consumption	Rm 202		2			
71	LAF-ONS-016	FIRST DRAW		Faucet, Cold	Non-Consumption	Rm 203		2			
72	LAF-ONS-017	FIRST DRAW		Faucet, Cold	Non-Consumption	Rm 204		2			
73	LAF-ONS-018	FIRST DRAW		Faucet, Cold	Non-Consumption	Rm 208		2			
74	LAF-ONS-019	FIRST DRAW		Faucet, Cold	Non-Consumption	Rm 209		2			
75	LAF-ONS-020	FIRST DRAW		Faucet, Cold	Non-Consumption	Rm 210		2			
76	LAF-ONS-021	FIRST DRAW		Drinking Water Fountain	Consumption	outside Rm 210	WF 4	2			
77	LAF-ONS-022	FIRST DRAW		Faucet, Cold	Consumption	Rm 217 teacher room		2			
78	LAF-ONS-023	FIRST DRAW		Faucet, Cold	Non-Consumption	Rm 243		2			
78	LAF-ONS-024	FIRST DRAW		Faucet, Cold	Non-Consumption	Rm 246		2			
80	LAF-HS-001	FIRST DRAW		Faucet, Cold	Non-Consumption	Loading dock(Mop sink)	MS	1			9AM
81	LAF-HS-002	FIRST DRAW		Spigot	Consumption	Locker Hall	HB 1	1			
82	LAF-HS-003	FIRST DRAW		Drinking Water Fountain	Consumption	girls Locker room	Wf 1	1			
83	LAF-HS-004	FIRST DRAW		Drinking Water Fountain	Consumption	Boys Locker room	Wf 2	1			
84	LAF-HS-005	FIRST DRAW		Drinking Water Fountain	Consumption	Gym Lobby	Wf3	1			
85	LAF-HS-006	FIRST DRAW	Bottle Filler	Water Cooler	Consumption	Gym Lobby	BF3	1			

Lafayette Central School District
PM: Shannon Weeks



HW03 added to each container
lot number - J432022 - 1/22/25

86	LAF-HS-007	FIRST DRAW		Ice Machine	Consumption				1			1/17	9am
87	LAF-HS-008	FIRST DRAW		Drinking Water Fountain	Consumption		Main Hall (girls rr)	Wf 4	1				
88	LAF-HS-009	FIRST DRAW	Bottle Filler	Water Cooler	Consumption		Main Hall (girls rr)	BF4	1				
89	LAF-HS-010	FIRST DRAW		Faucet, Cold	Consumption		Main office Sink		1				
90	LAF-HS-011	FIRST DRAW		Drinking Water Fountain	Consumption		Main Hall (Boys rr)	Wf 5	1				
91	LAF-HS-012	FIRST DRAW	Bottle Filler	Water Cooler	Consumption		Main Hall (Boys rr)	BF5	1				
92	LAF-HS-013	FIRST DRAW		Drinking Water Fountain	Consumption		Music hall	WF 6	1				
93	LAF-HS-014	FIRST DRAW	Bottle Filler	Water Cooler	Consumption		Music hall	BF 6	1				
94	LAF-HS-015	FIRST DRAW		Drinking Water Fountain	Consumption		Rm112 Choral Rm	WF 7	1				
95	LAF-HS-016	FIRST DRAW		Drinking Water Fountain	Consumption		Rm 114 Band Rm	WF8	1				
96	LAF-HS-017	FIRST DRAW		Faucet, Cold	Consumption		Rm117 Kitchen		1				
97	LAF-HS-018	FIRST DRAW		Drinking Water Fountain	Consumption		BP hall	WF 9	1				
98	LAF-HS-019	FIRST DRAW	Bottle Filler	Water Cooler	Consumption		BP Hall	BF 9	1				
99	LAF-HS-020	FIRST DRAW		Faucet, Cold	Consumption		129 - Nurse		1				
100	LAF-HS-021	FIRST DRAW		Faucet, Cold	Consumption		Rm 131 -S1		1				
101	LAF-HS-022	FIRST DRAW		Faucet, Cold	Consumption		Rm 131 -S2		1				
102	LAF-HS-023	FIRST DRAW		Faucet, Cold	Consumption		Rm 131 - S3		1				
103	LAF-HS-024	FIRST DRAW		Faucet, Cold	Consumption		Rm 131 -S4		1			✓	✓

Lafayette Central School District
PM: Shannon Weeks



J 5 A 0 6 1 7

HN03 added to each container
lot number - J432022 - 1/22/25 mrc

104	LAF-HS-025	FIRST DRAW		Drinking Water Fountain	Consumption		D-wing corridor	WF 10	1			1/17 9am
105	LAF-HS-026	FIRST DRAW		Faucet, Cold	Consumption		Rm 144		1			
106	LAF-HS-027	FIRST DRAW		Drinking Water Fountain	Consumption		2nd floor corr (girls rr)	WF11	2			
107	LAF-HS-028	FIRST DRAW		Water Cooler	Consumption		2nd floor corr (girls rr)	BF 11	2			
108	LAF-HS-029	FIRST DRAW		Faucet, Cold	Consumption		Rm 204 teach room		2			
109	LAF-HS-030	FIRST DRAW		Faucet, Cold	Non-Consumption		Rm 211 Lib		2			
110	LAF-HS-031	FIRST DRAW		Faucet, Cold	Non-Consumption		Rm 212		2			
111	LAF-HS-032	FIRST DRAW		Water Cooler	Consumption		2nd floor corr (boys rr)	BF 12	2			
112	LAF-HS-032	FIRST DRAW		Drinking Water Fountain	Consumption		Wellness	WF 13	B			
113	LAF-HS-033	FIRST DRAW		Water Cooler	Consumption		Wellness	BF 12	B			
114	LAF-HS-034	FIRST DRAW		Faucet, Cold	Non-Consumption		Concessions Sink					✓
115	LAF-DO-001	FIRST DRAW		Faucet, Cold	Consumption		Sink					✓ 9:30am
116												
117												
118												
119												
	HNO3 added to each Container			lot number - JH32022-1/22/25 mrc								

Anthony Vadala 1/17/25 12:35

Madison Card 1/17/25 12:39

17.3°C IR-1

07 08 07

