

LaFayette Central Schools Water Reporting

As required by County & State regulations, water samples were taken from District wells for analysis by Evan Todd, Safety Officer of OCM BOCES on November 17, 2021. The samples were then sent to Microbac Laboratories in Cortland.

The reports indicate that the water supplies were of a satisfactory, sanitary quality for all locations however, C. Grant Grimshaw school water supplies tested higher than 20mg/1 of sodium. Although there is not a set maximum level for sodium, it is recommended by the county that people on severely restricted sodium diets should be made aware.

Therefore for those that may be on a severely restricted sodium diet, it is recommended that caution be used when consuming the water from the C. Grant Grimshaw school.